

(C) (B) (A) (D)

To Pushbutton Station


(T5) (T1) (T2)

To Motor

NOTE:

All the assemblies include part # 33.4181 Enclosure and Contactor Assembly, with part # 33.1911 Control Circuit Transformer and # 33.1691 Aux Contact.

Assembly Part #	Overload #	Current Range
ER-2SB63	33.4341	4.0 - 6.3 AMPS
ER-2SC10	33.4361	6.3 - 10 AMPS
ER-2SC16	33.4381	10 - 16 AMPS



ATTENTION:
Line input must be installed on the bottom side of the overload and disconnect to meet requirements for UL Compliance in this starter.

HYTROL CONVEYOR CO., INC.
 2020 HYTROL DR.
 JONESBORO, ARKANSAS 72401

DESCRIPTION: Reversing 230 VAC Single Phase Combination Starter with Control Circuit Transformer

DRAWN BY: Roscoe Spencer

DATE: August 2, 2001

REVISION: 1

DWG. NO. ER-1PH23